

SNL MESA Project MicroLab RFQ Amendments Log

| Item | Vol. or Page | Drawing or Section Number | Comment/Question | Date | Response | Attach (Y/N) | Addendum Number | Date Closed |
|------|---------------------------------------|------------------------------|---|-----------|--|--------------|-----------------|-------------|
| 1 | paragraphs 1.04-B-1, 2.02, and 3.01-D | Specification Section 13852S | Specification Section 13852S paragraphs 1.04-B-1, 2.02, and 3.01-D discuss networking and compatibility with the existing fire alarm system, though no indication of this connection is made on the bid drawings. Is the MicroLab fire alarm system required to be networked and compatible with the MicroFab fire alarm system and the existing Building 858 Notifier fire alarm system? | 5/7/2003 | <p>Yes, the fire alarm system is required to be networked (Lab, Fab and 858 existing) and compatible.</p> <p>Dwg #FA7001858EL - The FACP shall be networked with the MicroFab FACP. The contractor shall provide a network communication line, network circuits (conduit and cabling), and connections per the specification. Contracotr shall closely coordinate the networking capabilities and pathway with the MicroFab contractor. Network circuits shall be compatible per the specifications.</p> | N | 1 | 5/19/2003 |
| 2 | PL6001858EL Seq. 165 | Drawing | <p>Elevator Sump Pump Schedule for SP5,6 & 7 call for Voltage/Phase for 203/3 and in 1/3 HP motor they do not make that voltage. Only 115V.</p> <p>This is the same for MESA Micro Fab Building for SP5 & 6.</p> | 5/9/2003 | Provide 1/3 HP pump use 115V, 1P. | N | 1 | 5/19/2003 |
| 3 | Comment | General | On the Mesa Microfab project we as general contractors were able to buy specific volumes of the drawings we may need from Albuquerque Graphics. IE, just the arch/struct volumes as some subs don't need the entire set with mech,elec,etc. Is it possible to do the same with the Microlab project. Mesa Reprographics says we can not do this. Thus if I or a sub only want the volume containing the arch/struct we have to purchase the entire set which is fairly cost prohibitive | 5/9/2003 | <p>The MicroFab drawings and specifications were not available to purchase specific volumes, only full size sets.</p> <p>For the MicroLab, contractors/vendors may purchase the CD option and have specific drawings or specifications printed.</p> <p>Refer to the How to Obtain Drawings and Specifications link.</p> | N | 1 | 5/19/2003 |
| 4 | Comment | RFQ | <p>Can subcontractor proposals be turned in later than the prime proposals?</p> <p>Will Sandia consider an increase to the bid page limit?</p> | 5/12/2003 | <p>Subcontractor best value criteria information may be turned in one day after the bid due date, June 20, 2003. Same submission instructions apply.</p> <p>Proposals shall not exceed 125 pages in length. Contractors are to decide the number of pages to devote to the bid and how many pages to devote to</p> | N | 1 | 5/19/2003 |

SNL MESA Project MicroLab RFQ Amendments Log

| Item | Vol. or Page | Drawing or Section Number | Comment/Question | Date | Response | Attach (Y/N) | Addendum Number | Date Closed |
|------|--------------|------------------------------|---|-----------|--|--------------|-----------------|-------------|
| | | | | | the subcontractor information. NOTE: Quotation Instruction #8 - SUBCONTRACTORS shall be finalized and turned in on the subcontractor information due date of June 20, 2003. | | | |
| 5 | 2.01A | Specification Section 15720S | Specification Section 15720S 2.01A lists acceptable manufacturers for the Air Handling Units to be "ENGINEERED AIR or engineer approved equal." We represent Haakon brand air handling units which were listed as acceptable for spect section 15720S in the MicroFab procurement phase. What is the procedure to allow Haakon as an equal for this phase of the project? | 5/12/2003 | For equipment that is not listed in the drawings or specifications as an acceptable brand, suppliers/vendors/manufacturers should contact the primes and/or subcontractors directly to propose submitting their product as a substitution (process explained below): PER CLAUSE #1 - STATEMENT OF WORK, PART C - OTHER CONDITIONS, #2: 2. Substitutions: The contractor shall bid on the equipment specified in the contract documents (Equipment List Drawings and Specifications). a. EQUIPMENT: i. If the contractor proposes to substitute, the contractor must provide: the base bid which includes the item specified and a proposed substitution sheet identifying each proposed substitution and the associated price change. ii. Contractor must show that the substituted item is "an equal" to the listed manufacture. No other substitutions will be accepted. | N | 1 | 5/19/2003 |
| 8 | Comment | General | Are European manufacturers allowed to provide equipment when the specifications indicate "or equivalent" for manufacturers, and the proposed | 5/12/2003 | Refer to CLAUSE #20 - BUY AMERICAN CERTIFICATION | N | 1 | 5/19/2003 |

SNL MESA Project MicroLab RFQ Amendments Log

| Item | Vol. or Page | Drawing or Section Number | Comment/Question | Date | Response | Attach (Y/N) | Addendum Number | Date Closed |
|------|--------------------------------------|---------------------------|---|-----------|---|--------------|-----------------|-------------|
| | | | European manufacturer meets of the technical requirements of the specification? | | | | | |
| 9 | Smoke Exhaust System Make Up Air Fan | Drawing | Smoke Exhaust System Make Up Air Fan issued for clarification | 5/15/2003 | Provide Make-up Air Fan support and platform, as illustrated on the attached drawings (Fan-1, Fan-2, Fan-3, Fan-4, Fan-5). | Y | 1 | 5/19/2003 |
| 16 | 10800 | Specification | Spec 10800 toilet accessories furnished by owner does not match the Sandia furnished material list in the front of the spec book nor the legend on sht 138. Which is correct? | 5/19/2003 | The Sandia furnished material list and sheet 138 are correct (Spec. 10800 is incorrect). | N | 1 | 5/19/2003 |